



## Clinton County Age-Friendly Business Evaluation

Inspired by Age-Friendly Columbus and Age-Friendly Cleveland

**Business name:**

**Address:**

Businesses should be evaluated on the following criteria: Parking, Entrance/Exit, Inside Area, Bathrooms, and Bathroom Fixtures. To become certified, businesses must answer "yes" to at least four indicators in each section.

<b>Parking</b>	<b>Yes</b>	<b>No</b>
Does the business have designated parking close to the entrance?		
Is there at least one marked accessible space?		
Are all sidewalks from parking to the main entrance equipped with adequate and well-maintained curb cuts?		
Is there sufficient lighting near parking?		
Is there a clear pickup/drop off area?		

**Score: \_\_\_ of 5**

**Notes:**

---

<b>Entrance/Exit</b>	<b>Yes</b>	<b>No</b>
Is there an entrance and exit without steps?		
Do the steps or ramps have a sturdy handrail?		
Does the door have a power opener?		
Does the door have a lever or loop handle rather than a knob?		
Is the width of the entrance/exit at least 32"?		

**Score: \_\_\_ of 5**

**Notes:**

---

<b>Inside Area</b>	<b>Yes</b>	<b>No</b>
Is the lighting sufficient to allow those with low vision to see items, displays, signage, and printed text?		
Is there a seating area that is accessible and has space to accommodate someone with a walker?		



## Clinton County Age-Friendly Business Evaluation

Inspired by Age-Friendly Columbus and Age-Friendly Cleveland

Is there a path of travel at least 36" wide and able to accommodate a wheelchair?		
Is the ground flat and not slippery?		
Is there a portion of the sales counter that is no higher than 36" and allows someone with a wheelchair to approach it?		

**Score: \_\_\_ of 5**

**Notes:**

---

<b>Restrooms</b>	<b>Yes</b>	<b>No</b>
Is there a public bathroom?		
Is there a bathroom located on the main level of the business or accessible by an elevator on an upper level?		
Is there a restroom stall at least 60" wide to accommodate a wheelchair?		
Does the stall door provide at least 32" of a clear opening?		
Does the bathroom sign have Braille and raised tactile text?		

**Score: \_\_\_ of 5**

**Notes:**

---

<b>Restroom Fixtures</b>	<b>Yes</b>	<b>No</b>
Does the stall door have loop handles to allow easy opening and closing?		
Is there knee clearance at least 27" high under the sink?		
Is the sink counter no higher than 34"?		
Do the faucets have lever handles or motion sensor features rather than having knobs?		
Are paper towel and soap dispensers and other amenities like coat hooks and light switches no higher than 48" above the floor?		

**Score: \_\_\_ of 5**

**Notes:**

---